

# Economic dispatch of a single micro gas turbine under CHP operation with uncertain demands

Miel Sharf<sup>a,\*</sup>, Iliya Romm<sup>b</sup>, Michael Palman<sup>b</sup>, Daniel Zelazo<sup>b</sup>, Beni Cukurel<sup>b</sup>

<sup>a</sup> Division of Decision and Control Systems, KTH Royal Institute of Technology, and Digital Futures, 10044 Stockholm, Sweden

<sup>b</sup> Department of Aerospace Engineering, Technion - Israel Institute of Technology, Haifa, Israel

## ARTICLE INFO

### Keywords:

Micro gas turbines  
Combined Heat and Power (CHP)  
Economic dispatch  
Microgrids  
Uncertain demand  
Robust optimization

## ABSTRACT

This work considers the economic dispatch problem for a single micro gas turbine, governed by a discrete state-space model, under combined heat and power (CHP) operation and coupled with a utility. If the exact power and heat demands are given, existing algorithms can be used to give a quick optimal solution to the economic dispatch problem. However, in practice, the power and heat demands cannot be known deterministically, but are rather predicted, resulting in an estimate and a bound on the estimation error. We consider the case in which the power and heat demands are unknown, and present a robust optimization-based approach for scheduling the turbine's heat and power generation, in which the demand is assumed to be inside an uncertainty set. We consider two different choices of the uncertainty set relying on the  $\ell^\infty$ - and the  $\ell^1$ -norms, each with different advantages, and consider the associated robust economic dispatch problems. We recast these as robust shortest-path problems on appropriately defined graphs. For the first choice, we provide an exact linear-time algorithm for the solution of the robust shortest-path problem, and for the second, we provide an exact quadratic-time algorithm and an approximate linear-time algorithm. The efficiency and usefulness of the algorithms are demonstrated using a detailed case study that employs real data on energy demand profiles and electricity tariffs.

## 1. Introduction

In recent years, combined cycle systems, in which local consumers provide electricity, hot water and heat for themselves, have become popular [1]. The attractiveness of such combined heating and power (CHP) units was shown in recent studies [2,3], and the economically favorable conditions toward integrating micro gas turbines (MGT) powered CHP units into the smart-grid was examined in [4,5]. However, these works consider a generic MGT model and do not include realistic demand profiles nor the variable pricing of electricity. More recently, [6] presented a solution to the CHP economic dispatch (ED) problem for a single MGT coupled to the utility with a realistic MGT performance model and known demand, i.e., an economically-optimal schedule of the MGT was computed for a consumer generating its own power and heat. In this paper, we propose a solution to a similar economic dispatch problem for the case of unknown demand by using the framework of robust optimization.

### 1.1. Micro gas turbines

Micro gas- turbines (MGT) offer many advantages for small-scale CHP production, such as low greenhouse gas emissions, theoretical high thermal efficiency and reduced noise. They are also capable of short start-up times and rapid transitions between partial and full-load, due to their low mechanical and thermal inertia. For these reasons, [4,5] examined the economically favorable conditions of integrating MGTs into the smart-grid. However, theoretical analysis of MGTs, especially in an economic framework, can be hard due to physical limitations. These include, but are not limited to:

- (i) Many MGTs can only shutdown from or startup to certain operation levels [7,8].
- (ii) When some MGTs are turned off, they must be cooled down before they can be turned on again. For example, the Capstone C65 MGT must cool down for up to 10 min before coming online again [7].
- (iii) Even when the turbines are active, not any generation level between the maximum and minimum capacity is allowed. This

\* Corresponding author.

E-mail addresses: [sharf@kth.se](mailto:sharf@kth.se) (M. Sharf), [iliya@technion.ac.il](mailto:iliya@technion.ac.il) (I. Romm), [p.michael@technion.ac.il](mailto:p.michael@technion.ac.il) (M. Palman), [dzelazo@technion.ac.il](mailto:dzelazo@technion.ac.il) (D. Zelazo), [beni@cukurel.org](mailto:beni@cukurel.org) (B. Cukurel).

<https://doi.org/10.1016/j.apenergy.2021.118391>

Received 29 August 2021; Received in revised form 5 November 2021; Accepted 13 December 2021

0306-2619/© 2022 The Authors. Published by Elsevier Ltd. This is an open access article under the CC BY license (<http://creativecommons.org/licenses/by/4.0/>).

is due to structural and rotordynamic resonances rendering the engines unstable or unsafe for certain rotation speeds [6,9–11].

- (iv) From an aerodynamic perspective, compressor blade fluttering introduces additional permeating operational boundaries, which may interrupt the continuity of engine's operating line [12,13].
- (v) Gas turbine emissions such as carbon monoxide (CO), unburned hydrocarbons (UHC) and nitric oxides (NOx) cause an increasing concern. Percentage of CO, HC, NOx is directly correlated to the combustor temperature, equivalent ratio and pressure [14], which are highly variant throughout engine's operating region. Towards reducing the amount of emissions, authorities impose strict regulations on gas turbine operators, which create zones in the operating line which are undesirable. Furthermore, the majority of modern engines with reduced emissions are operating with lean combustion, which is more prone to exhibit thermoacoustic instability (interaction between an acoustic field and a combustion process that increases pressure oscillations that may even lead to complete failure of the gas turbine unit). [15,16]. Then, avoiding the combustor thermoacoustic instabilities also impose additional discontinuities in engine's operational field.

Any thorough economic analysis of a system including MGTs, including economic viability of MGTs or optimal generation planning, must account for the physical limitations of the MGT.

### 1.2. Economic analysis of power generation

The economic analysis of power generation is usually done by considering the Economic Dispatch (ED) optimization problem. Generally, ED considers a collection of supply mechanisms generating power and/or heat, where the goal is to schedule the machines' generation to guarantee that the demand is met, while minimizing the overall production costs [17]. This paper considers the ED problem for a single MGT and a utility, from which both power and heat can be purchased.<sup>1</sup> Thus, the ED problem must account for the physical limitations (i)–(iii), as well as other physical limitations that the particular MGT model might possess.

Economic dispatch has been considered for many different types of systems, including steam engines, gas turbines, and wind turbines [6, 18,19]. Most literature on ED simulate the generators as having continuous states based on first principle modeling of the system, where the generated power and heat can take any value between a minimum and a maximum capacity, and the corresponding cost function, mapping generation level to economic cost, is assumed to be quadratic [18, 19]. The resulting ED problem is usually solved using standard convex optimization techniques, e.g. gradient descent or dual-gradient methods [19,20]. These methods can also be combined with other techniques, e.g. consensus-based algorithms [21]. More recent works try to apply learning-based approaches [22,23] or particle swarm optimization methods [24,25] to solve the convex optimization problem. The reader is referred to the following recent reviews on the subject for more information and Refs. [26,27].

Unfortunately, this convex optimization framework fails to capture the fundamental constraints imposed by the physical limitations of MGTs, e.g. points (i)–(v) described in Section 1.1, unless augmented properly, for multiple reasons. First, in a low-demand scenario, not all providers should be active, so we should also schedule their startup and shutdown. This is usually done by considering the unit commitment (UC) problem [28]. However, due to the flexibility of MGTs and their quick start up and shutdown times, as well as the physical limitation (i), this decoupling will result in a wasteful scheduling policy.

Therefore, we do not decouple the UC and ED problems, and instead incorporate the inactive state into the ED problem. This is usually done by introducing binary variables determining when the machines should be active [18,19]. Moreover, the physical limitation (ii) implies we need more than one inactive state per MGT. Furthermore, the physical limitations (iii)–(v) mean that we cannot model the generation of the turbine (when active) as a continuous variable with minimum and maximum capacities. Other turbine-specific limitations can impose additional constraints on the model.

### 1.3. Shortest-path algorithms and uncertain demand

Combining the restrictions described above, we get a model for the MGT having multiple discrete (inactive) states and complex constraints on the allowed generation level when active, meaning that the ED problem is a constrained mixed-integer problem, which can be NP-hard in general. One possible solution is to discretize the state space and cost function, which works well for complex engine models, as the fuel consumption can be computed numerically. In this setting, the combined UC and ED problem is a discrete-time optimal control problem with a discrete state–space representation for the plant. This is an integer optimization problem where generated power and heat can only take values within a finite set. A solution to this problem is available using dynamic programming, namely by using the shortest-path algorithm on an appropriately defined graph [6,29]. However, this method, as well as most other approaches for ED, assumes the demands are known throughout the time horizon [6,19,20,30–33], e.g. by using one of the many load forecasting techniques that appear in the literature, see e.g. [34–37] and references therein.

One might try to simply ignore the issue of unknown future demands by solving the ED problem with respect to an ad-hoc estimate of the demand level. However, this approach can fail miserably, as is known that for some real-world optimization problems, the optimal solution changes drastically when some parameters in the problem change even by a minuscule amount [38,39]. Another approach to overcome this problem is to consider a stochastic optimization framework, in which we try and minimize the average cost of generation [40–42]. These require prior knowledge on the probability distribution of the underlying uncertainty, which must be estimated from past data, resulting again in the same problem of parameter inaccuracy. Another approach taken by recent studies is the incorporation of robust optimization techniques, in which the demand is assumed to be in a given set, which is known as the “uncertainty set”. The choice of uncertainty set requires us to have knowledge about the possible values the demand can take, which again results in a problem of parameter inaccuracy. Fortunately, there is evidence that robust algorithms for general problems are significantly less vulnerable to parameter uncertainty [43]. However, robust shortest-path problems are known to be generally NP-hard [44], meaning that a careful treatment of the problem and the uncertainty set is needed to assure that the resulting optimization problem is tractable. We discuss in detail about previous results regarding robust shortest-path problems in Section 2.4 below, but all existing solution methods are either overconservative or suffer from very prolonged runtimes even for small graphs with a few hundred nodes. For comparison, the MGT ED problem with known demand in [6] is converted to a shortest-path problem on a graph with roughly 250,000 nodes.

### 1.4. Contributions

In this work, we consider the ED problem of a single MGT with a known discrete state–space representation, and unknown power and heat demands. The turbine is also connected to a utility from which power and heat can be purchased at a time-dependent cost<sup>1</sup>. We apply the robust optimization framework for the mixed-integer ED problem, which results in a robust shortest-path problem. We study multiple

<sup>1</sup> Heat is not directly sold by the utility, but can be modeled as an additional fuel or electricity cost. Most consumers satisfy their heat demand with a boiler, in which case we model the heating cost with the price of natural gas.

possible choices for the uncertainty set. In the first case, the demand at each time is within a given confidence interval. In the second case, we similarly restrict the demand at each time to lie inside confidence intervals with given centers and radii, but a certain bound (a “budget”) is put on the aggregate deviation of the demand from the interval centers throughout the time horizon, i.e. the uncertainty is “budgeted” throughout the time horizon. In both cases, we present linear-time algorithms for finding the optimal solution, and prove their validity. To the best of the authors’ knowledge, the algorithms we present are the first to give a tractable solution to the robust shortest path problem when the edge costs are positively correlated (see Section 2.4 for more details).

The paper is structured as follows. Section 2 presents some background about ED, the shortest-path problem and robust optimization, as well as a literature review on the robust shortest path problem. Section 3 considers the robust ED problem as a worst-case shortest-path problem, including multiple possible cases for the uncertainty set, and presents efficient algorithms for solving the robust ED problem in these cases. Section 4 portrays a case study demonstrating the algorithms.

**Preliminaries.** We let  $\mathbb{N} = \{1, 2, \dots\}$  be the set of all natural numbers. We use notions from graph theory [45]. A directed graph  $\mathcal{G} = (\mathcal{V}, \mathcal{E})$  consists of a finite set of vertices  $\mathcal{V}$  and a set of edges  $\mathcal{E}$  which are pairs of vertices of  $\mathcal{V}$ . An edge from  $u \in \mathcal{V}$  to  $v \in \mathcal{V}$  will be denoted as  $u \rightarrow v$ , where  $u$  is the tail of the edge and  $v$  is its head. A path from a vertex  $u$  to a vertex  $v$  is a sequence of edges  $e_1, \dots, e_\ell$  such that  $u$  is  $e_1$ ’s tail,  $v$  is  $e_\ell$ ’s head, and for any  $i$ ,  $e_i$ ’s head is  $e_{i+1}$ ’s tail. A directed graph  $\mathcal{G}$  is called a DAG (directed acyclic graph) if there are no paths which begin and end at the same vertex. For a node  $v \in \mathcal{V}$ , the in-degree  $\deg(v)$  is the number of edges  $e \in \mathcal{E}$  which have  $v$  as a head. As each edge has exactly one head, we have that  $\sum_{v \in \mathcal{V}} \deg(v) = |\mathcal{E}|$ . A weighted directed graph is a triplet  $(\mathcal{V}, \mathcal{E}, w)$  where  $(\mathcal{V}, \mathcal{E})$  is a directed graph and  $w : \mathcal{E} \rightarrow \mathbb{R}$  is called the weight function. The cost of a path is defined as the sum of the weights of its edges. The shortest path problem for a graph  $\mathcal{G}$  is a combinatorial optimization problem in which the goal is to find the path with the smallest cost from a node  $s$  to a node  $q$ .

We consider some notions from convex analysis [46]. For a convex set  $\mathcal{W} \subset \mathbb{R}^d$ , we say  $x \in \mathcal{W}$  is an *extreme point* if for any  $y, z \in \mathcal{W}$  and any  $t \in (0, 1)$ , if  $x = ty + (1 - t)z$  then  $x = y = z$ . The collection of extreme points of  $\mathcal{W}$  is denoted by  $\text{ext}(\mathcal{W})$ . If  $f : \mathcal{W} \rightarrow \mathbb{R}$  is a convex function and  $\mathcal{W}$  is bounded and closed, it is known that  $\max_{x \in \mathcal{W}} f(x) = \max_{x \in \text{ext}(\mathcal{W})} f(x)$  [46, Theorem 32.2]. For a norm  $\|\cdot\|$  on  $\mathbb{R}^N$ , the norm ball of radius  $r > 0$  around  $x_0 \in \mathbb{R}^N$  is equal to  $\{x \in \mathbb{R}^N : \|x - x_0\| \leq r\}$ . Moreover, a weighted  $\ell^\infty$  norm on  $\mathbb{R}^N$  is given by  $\|x\| = \max_{i=1}^N \{w_i |x_i|\}$  where  $w_1, \dots, w_N > 0$  are the associated weights. Similarly, a weighted  $\ell^1$ -norm is given by  $\|x\| = \sum_{i=1}^N w_i |x_i|$ . The Minkowski sum of two sets  $A, B$  is given by  $A + B = \{a + b : a \in A, b \in B\}$ .

## 2. Turbine models, ED, and robust optimization

This section provides the required background material, including a model for the MGT, the ED and shortest-path problems, and some basic notions from robust optimization.

### 2.1. Discrete state-space models for turbines

We consider a micro gas turbine (MGT) with a discrete state space, which is a generalization of [6]. Due to the low mechanical and thermal inertia of the proposed class engine and with sufficiently high discretization resolution, transition time between engine states becomes negligible. Therefore, only MGT steady states are considered. We denote the state space of the MGT by  $\mathcal{X}$ , which is assumed to be a finite set. The state  $x(t)$  of the turbine evolves in discrete time. The dynamics can be modeled by two functions  $f, c$  and a state-indexed set  $\mathcal{U}(x)$ , i.e., for each  $x \in \mathcal{X}$ , we denote the set of admissible control signals by  $\mathcal{U}(x)$ . The function  $f(x, u)$  describes the allowable transitions

between turbine states, and the function  $c(x, u)$  describes the transition times between states. More precisely, we assume that the function  $c(x, u) \in \mathbb{N}$  for all pairs  $(x, u)$ , and consider the equation governing the state evolution of the turbine:

$$x(t + c(x(t), u(t))\Delta t) = f(x(t), u(t)),$$

where  $u(t)$  is the control input at time  $t$  and  $\Delta t$  is the time increment. In other words, if the control input  $u(t)$  is applied at the state  $x(t)$ , the next state will be  $f(x(t), u(t))$  and it will take  $c(x(t), u(t))\Delta t$  time to get there. As  $c(x, u) \in \mathbb{N}$  for all pairs  $(x, u)$ , the state  $x(t)$  evolves at time  $0, \Delta t, 2\Delta t, \dots$

For each state  $x$  and control input  $u$ , we let  $P_{\text{MGT}}(x, u)$  be the power generation associated with the state-control pair  $(x, u)$  for one time step  $\Delta t$ , and let  $H_{\text{MGT}}(x, u)$  be the heat generation associated with the same state-control pair for one time step  $\Delta t$ . For example, let  $x \in \mathcal{X}$  be a state in which the turbine is switched off, and  $u$  is a control input for which  $f(x, u) = x$ , i.e. the turbine is also switched off at the next time step, then  $P_{\text{MGT}}(x, u) = H_{\text{MGT}}(x, u) = 0$ . We emphasize that both the power and heat generation can also depend on  $u$ . Indeed, because  $P_{\text{MGT}}$  and  $H_{\text{MGT}}$  aggregate the generation between two times  $t_0$  and  $t_0 + \Delta t$ , the control  $u(t_0)$  does not only determine the state of the turbine at time  $t_0 + \Delta t$ , but also the generated amount in the intermediate time. Indeed, the turbine generates power in continuous-time, even though our model is discrete-time.

**Remark 1.** The discretization methodology presented is general for any micro gas turbine, and does not inherently assume a specific physical model while solving the ED problems in Section 3. More precisely, given any data set predicting the performance of the turbine analytically, numerically or empirically, we can achieve a discrete model by choosing a grid for each of the turbine parameters that define its state. Then, we compute the power output  $P_{\text{MGT}}(x, u)$ , the heat output  $H_{\text{MGT}}(x, u)$ , and the fuel flow consumed by the turbine for each possible transition between two states. The fuel flow consumption defines the cost of operating the turbine, and is described in Section 2.2. Moreover, we can choose to impose certain generation or ramp-rate constraints by limiting either the allowable physical state, the allowable control actions, or pairs thereof before performing the discretization.

**Example 1.** Consider the MGT model in [6], consisting of a single stage centrifugal compressor, a can-type combustor, a single stage turbine, a recuperator and a separate heat recovery unit. There, the active states of the turbine are characterized by two parameters,  $p$  and  $h$ . The variable  $p$  is the speed of the engine, and can take values  $p_1, \dots, p_s$ , while the variable  $h$  is the position of a recuperator bypass valve, and can take values  $h_1, \dots, h_v$ , so  $\mathcal{X} = \{(p_i, h_j) : i = 1, \dots, s, j = 1, \dots, v\}$ . The allowable transitions change the speed of the engine, the recuperator bypass valve position, or both by one level. Changing the position of the valve or slowing down the engine takes one unit of time (i.e.  $c(x, u) = 1$  in this case), while revving up the engine takes two units of time (so  $c(x, u) = 2$  for this transition).

**Example 2.** Consider a turbine that generates  $p$  units of power and  $h$  units of heat when active. When the turbine is on, it can be turned off at any time, within 15 s. However, once it is turned off, it has a cool-down time of 45 s (i.e., three time steps). We model the turbine using a discrete state-space representation with time instances  $\Delta t = 15$  s apart and with  $|\mathcal{X}| = 4$  possible states - one active state,  $x_{\text{on}}$ , and three off states,  $x_{\text{off},1}, x_{\text{off},2}, x_{\text{off},3+}$ , which represent that the turbine has been inactive for 1, 2, or at least 3 units of time, respectively. Here,  $\mathcal{U}(x_{\text{on}}) = \{\text{keep}, \text{shutdown}\}$ ,  $\mathcal{U}(x_{\text{off},3+}) = \{\text{keep}, \text{start}\}$ , and  $\mathcal{U}(x_{\text{off},1}) = \mathcal{U}(x_{\text{off},2}) = \{\text{keep}\}$ . The control signal “keep” moves  $x_{\text{on}}$  to itself,  $x_{\text{off},1}$  to  $x_{\text{off},2}$ ,  $x_{\text{off},2}$  to  $x_{\text{off},3+}$  and  $x_{\text{off},3+}$  to itself. Moreover, the control signal “shutdown” moves  $x_{\text{on}}$  to  $x_{\text{off},1}$ , and the control signal “start” moves  $x_{\text{off},3+}$  to  $x_{\text{on}}$ . These transitions all take one time step, i.e.  $c(x, u) = 1$  for all pairs  $(x, u)$ . The possible evolution of the state  $x(t)$  of the turbine across 5 time steps can be seen in Fig. 1.




Fig. 1. The state transition graph corresponding to the ED problem for the turbine in Example 2 with time horizon  $T = 5$ .

## 2.2. Economic dispatch and the shortest-path problem

The ED problem aims at scheduling the generation of the turbine throughout a time horizon  $T$  as to minimize the cost while generating the required amount of heat and power. For each state-control pair  $(x, u)$ , we define  $C_{\text{MGT}}(x, u)$  as the total cost of operating the turbine for  $c(x, u)$  units of time, starting at state  $x$  and issuing the control input  $u$ . In other words, this is the cost of the transition defined by the state-control pair  $(x, u)$ . We let  $(P(t), H(t))_{t=1}^T$  be the power and heat demand, which are known throughout the time horizon.

Besides the turbine, we can also draw power and heat from a utility. For a time  $t$ , we denote the power and heat purchased from the utility by  $x_U^P(t)$  and  $x_U^H(t)$  respectively. The cost of purchasing  $x_U^P(t)$  units of power and  $x_U^H(t)$  units of heat from the utility at time  $t$  is denoted by  $C_{U,t}^P(x_U^P(t))$ ,  $C_{U,t}^H(x_U^H(t))$  respectively. We assume the cost function  $C_{U,t}^P$  is defined for  $x_U^P$ , which corresponds to the case in which the MGT tries to sell power to the utility, and an infinite cost corresponds to inability to sell power. Moreover, we assume the function  $C_{U,t}^H$  is defined for  $x_U^H < 0$  and satisfies  $C_{U,t}^H(x_U^H) = 0$ . In other words, we can exhaust excess generated heat with no extra cost. We further assume that the functions  $C_{U,t}^P, C_{U,t}^H$  are non-decreasing on the sets  $\{x_U^P \in \mathbb{R} : C_{U,t}^P(x_U^P) < \infty\}$  and  $\{x_U^H \in \mathbb{R} : C_{U,t}^H(x_U^H) < \infty\}$  respectively, i.e. that buying more power and heat from the utility will cost more, and that selling power to the utility (if possible) will earn more. The ED problem is defined as follows:

$$\begin{aligned} \min \quad & \sum_{t=1}^T [C_{\text{MGT}}(x(t), u(t)) + C_{U,t}^P(x_U^P(t)) + C_{U,t}^H(x_U^H(t))] \\ \text{s.t.} \quad & x(t + c(x(t), u(t))\Delta t) = f(x(t), u(t)), \quad \forall t = 1, \dots, T \\ & P_{\text{MGT}}(x(t), u(t)) + x_U^P(t) = P(t), \quad \forall t \\ & H_{\text{MGT}}(x(t), u(t)) + x_U^H(t) = H(t), \quad \forall t \\ & x(t) \in \mathcal{X}, \quad u(t) \in \mathcal{U}(x(t)), \quad x_U^P(t), x_U^H(t) \in \mathbb{R}, \quad \forall t \end{aligned} \quad (1)$$

This problem is evidently a nonlinear mixed-integer problem. However, [6] offers a quick solution method using a directed graph  $\mathcal{G} = (\mathcal{V}, \mathcal{E})$ . The vertices are given by the pairs  $(t, x)$  where  $t \in \{1, \dots, T\}$  and  $x \in \mathcal{X}$ . For a fixed time  $t$ , the nodes  $\{(t, x)\}_{x \in \mathcal{X}}$  designate the state of the turbine at time  $t$ . As for the edges,  $e = (t_1, x_1) \rightarrow (t_2, x_2) \in \mathcal{E}$  if there is some  $u_1 \in \mathcal{U}(x_1)$  such that  $f(x_1, u_1) = x_2$  and  $t_2 = t_1 + c(x_1, u_1)$ . The cost of said edge is defined as the total cost of the transition, given by

the following expression:

$$w_e = C_{\text{MGT}}(x_1, u_1) + \sum_{t=t_1}^{t_2} [C_{U,t}^P(P(t) - P_{\text{MGT}}(x_1, u_1)) + C_{U,t}^H(H(t) - H_{\text{MGT}}(x_1, u_1))]. \quad (2)$$

The edges and their cost represent the possible transitions for the turbine. For example, the corresponding graph for the turbine in Example 2 with time horizon  $T = 5$  can be seen in Fig. 1. Thus, a possible trajectory  $(x(t))_{t=1}^T$  of the state of the turbine corresponds to a *path* in the graph.<sup>2</sup> If we define the cost of a path as the sum of the costs of the corresponding edges, we get a one-to-one correspondence between paths on the graph  $\mathcal{G}$  and generation schedules of the turbine, in which the total cost of a schedule is identical to the cost of the corresponding path. Therefore, the ED problem can be restated as finding the cheapest path from some node  $(1, x)$  to some other node  $(T, y)$ , where  $x, y \in \mathcal{X}$  are the initial and final state of the turbine.

Suppose we add a node  $s$  (called the source node) and a node  $q$  (called the terminal node) to the graph, and add edges  $s \rightarrow (1, x)$ ,  $(T, x) \rightarrow q$  from all  $x \in \mathcal{X}$  having zero weight. Any path from some node  $(1, x)$  to some other node  $(T, y)$ , where  $x, y \in \mathcal{X}$ , uniquely defines a path from  $s$  to  $q$ . Moreover, these paths share the same cost. Thus, the ED problem can be understood as finding the cheapest path from  $s$  to  $q$ , known as the *shortest path problem* [29]. If we denote the set of all paths from  $s$  to  $q$  in  $\mathcal{G}$  by  $\text{PATH}_{s \rightarrow q}(\mathcal{G})$ , we get the following optimization problem in the variable  $\text{Path}_{s \rightarrow q}$ :

$$\min_{\text{Path}_{s \rightarrow q}} \left\{ \sum_{e \in \text{Path}_{s \rightarrow q}} w_e : \text{Path}_{s \rightarrow q} \in \text{PATH}_{s \rightarrow q}(\mathcal{G}) \right\}. \quad (3)$$

As  $\mathcal{G}$  is a directed acyclic graph (DAG), standard dynamic programming methods solve this problem quickly, with computational complexity equal to  $O(|\mathcal{E}|)$ . Moreover, standard graph theory software provides implementation of said methods. Thus, the ED problem for an MGT can be solved quickly using off-the-shelf software.

However, this approach is inapplicable if the demands are unknown and the weights of the edges cannot be determined accurately. Usually an estimate on the demand throughout the horizon is known, so it is tempting to try and solve this problem with the estimate, disregarding the estimation error. However, the optimal solution to many complex real-life optimization problems can perform poorly when the parameters of the problems are changed by even a minuscule amount [38,39]. This motivates using tools from robust optimization, giving a bound on the worst-case behavior of a proposed solution.

## 2.3. Robust optimization

Consider a minimization problem in the variable  $x$ , where both the cost function  $F(x, \xi)$  and constraints  $\phi(x, \xi) \leq 0$  are affected by an uncertain variable  $\xi \in \Xi$ , where the inequalities are understood component-wise. In our case, the uncertain variables are the power and heat demands. In classical robust optimization, we choose a subset  $\mathcal{W} \subseteq \Xi$  defining all possible values of the uncertainty we consider, coined the *uncertainty set*, and define the worst-case optimization problem [38]:

$$\min_x \max_{\xi \in \mathcal{W}} \{F(x, \xi) : \phi(x, \xi) \leq 0, \quad \forall \xi \in \mathcal{W}\}.$$

This optimization problem assures that the solution is feasible for any value of the uncertainty within the uncertainty set, and gives a bound on its cost. However, checking that  $\phi(x, \xi) \leq 0$  for any  $\xi \in \mathcal{W}$  is usually very hard or even impossible if  $\mathcal{W}$  is infinite. Instead, we reformulate the constraint as  $\sup_{\xi \in \mathcal{W}} \phi(x, \xi) \leq 0$ , which is easier to verify if the supremum can be computed analytically. For example, if  $\phi$  is a bi-linear

<sup>2</sup> See the notations section for a precise definition of a path in a graph.



function and  $\mathcal{W}$  is defined using finitely many linear inequalities, the constraint can be reformulated to be linear. A common choice for  $\mathcal{W}$  is  $\mathcal{W} = \{\xi : \|\xi\| \leq \delta\}$  for some norm  $\|\cdot\|$ , for which the supremum can be computed using the dual norm, defined as  $\|\eta\|_* = \sup_{\|\xi\| \leq 1} \xi^T \eta$  [38]. Common choices for  $\|\cdot\|$  are the  $p$ -norm for  $p = 1, 2, \infty$ , for which the dual norm is  $q$ -norm with  $q = \infty, 2, 1$  correspondingly. The parameter  $\delta$  must be tuned accordingly to avoid over-conservatism as well as over-optimism. See [43] for more on the implications of choosing a specific uncertainty set.

#### 2.4. Robust shortest-path problems

The shortest path problem (3) depends on two parameters - the graph  $\mathcal{G}$ , and the edge weights  $\{w_e\}_{e \in \mathcal{E}}$ . The robust shortest-path problem studies the case in which the edge weights are unknown, but are assumed to lie inside a set  $\mathcal{W} \subseteq \mathbb{R}^{|\mathcal{E}|}$ , coined as the “uncertainty set”. More specifically, the problem aims to minimize the worst-case cost:

$$\min_{\text{Path}_{s \rightarrow q}} \max_{w \in \mathcal{W}} \left\{ \sum_{e \in \text{Path}_{s \rightarrow q}} w_e : \text{Path}_{s \rightarrow q} \in \text{PATH}_{s \rightarrow q}(\mathcal{G}) \right\}. \quad (4)$$

The edge weights are said to be uncorrelated if there exist sets  $\mathcal{W}_e \subseteq \mathbb{R}$  for all  $e \in \mathcal{E}$  such that  $\mathcal{W} = \{w \in \mathbb{R}^{|\mathcal{E}|} : w_e \in \mathcal{W}_e\}$ , i.e. knowing the cost of some edge does not give any more information about the cost of other edges. It is known that the robust shortest path problem for a general uncertainty set  $\mathcal{W}$  is NP-hard [44]. For that reason, several works in the literature proposed uncertainty sets  $\mathcal{W}$  which lead to tractable problems.

In [47,48], the authors assume edge costs are uncorrelated, and choose an uncertainty set consisting of confidence intervals for the cost without budgeting the uncertainty, i.e., the uncertainty set was taken as  $\mathcal{W} = \{w \in \mathbb{R}^{|\mathcal{E}|} : \text{lower}_e \leq w_e \leq \text{upper}_e\}$ . Hence, the achieved solution is also robust against the case in which all edges incur the maximum possible cost, rendering it vastly overconservative for real-world scenarios in many applications. This issue is addressed in [49], in which a budgeted uncertainty set is considered by bounding the amount of edges whose cost can be different than the nominal value. This method cannot be applied to the problem of ED, as the costs of the edges are demand-dependent, and in practice, the demand will be different from our estimate at any time step, even if by a small amount. More recent works consider either a more complex uncertainty budgeting mechanism [50], or a more sophisticated robustification method [51]. However, the former can yield NP-hard problems, while the latter yields problems which take a long amount of time to solve in practice, even for small graphs with only hundreds of nodes [51]. For ED, the problem in [6] is converted to a shortest-path problem on a graph with roughly 250,000 nodes, rendering the approach of [51] as inapplicable. Moreover, all of these methods assume that the edge costs are either uncorrelated or negatively correlated with each other (i.e., if the cost  $w_{e_1}$  significantly deviates from its mean, then the cost  $w_{e_2}$  is less likely to deviate from its mean). However, in shortest-path problems inspired by economic dispatch, e.g. in [6], the costs of edges corresponding to the same time step are positively correlated, as both are determined by the demand at the corresponding time step, and a larger demand leads to a larger cost. These reasons motivate the derivation of the algorithms presented in Section 3.

### 3. Robust economic dispatch with uncertain demands

Consider an ED problem of the form (1), where the demand  $\xi = (P(t), H(t))_{t=1}^T$  is assumed to be unknown. Assume further that the true demand profile is contained in a set  $\mathcal{W} \subseteq \mathbb{R}^{2T}$ . Note that in the ED problem, the turbine variables  $x(t), u(t)$  must be scheduled in advance, after which the true demand is revealed and the utility variables  $x_U^P(t), x_U^H(t)$  are computed from the power- and heat-balance equations,

$x_U^P(t) = P(t) - P_{\text{MGT}}(x(t), u(t))$  and  $x_U^H(t) = H(t) - H_{\text{MGT}}(x(t), u(t))$ . In other words, the turbine variables  $x(t), u(t)$  are treated as initial decision variables, and  $x_U^P(t), x_U^H(t)$  are therefore viewed as recourse variables. We use the graph-based interpretation of the problem. For every edge  $e \in \mathcal{E}$ , we let  $w_e(\xi)$  be equal to (2), where  $\xi = (P(t), H(t))_t = 1^T$ .

$$\begin{aligned} \min_{\text{Path}_{s \rightarrow q}} \max_{\xi \in \mathcal{W}} \sum_{e \in \text{Path}_{s \rightarrow q}} w_e(\xi) \\ \text{s.t. } \text{Path}_{s \rightarrow q} \in \text{PATH}_{s \rightarrow q}(\mathcal{G}). \end{aligned} \quad (\text{RSPP})$$

The main focus of this section is to study the tractability of (RSPP) as a consequence of the choice of  $\mathcal{W}$ .

#### 3.1. Positively-extreme profiles and $\mathcal{L}_\infty$ -based uncertainty

The tractability of (RSPP) boils down to the following question - what demand profiles  $\xi$  are the worst-case for a specific path in the graph  $\mathcal{G}$ ? Intuitively, the higher the demand, the higher the generation cost. It is easy to see by (2) that if  $P_1(t) \leq P_2(t)$  and  $H_1(t) \leq H_2(t)$  for all  $t$ , then  $w_e(\xi_1) \leq w_e(\xi_2)$  for every  $e \in \mathcal{E}$ , where  $\xi_i = (P_i(t), H_i(t))_{t=1}^T$  for  $i = 1, 2$ . Thus, for any  $\xi_1, \xi_2 \in \mathbb{R}^{2T}$ , we have:

$$(\xi_1)_k \leq (\xi_2)_k, \forall k = 1, \dots, 2T \implies w_e(\xi_1) \leq w_e(\xi_2). \quad (5)$$

This suggests the following definition:

**Definition 1.** Let  $\mathcal{W} \subseteq \mathbb{R}^{2T}$  be any set. We say that  $\xi \in \mathcal{W}$  is *positively extreme* if for all  $\zeta \in \mathcal{W}$  there exists some  $k$  such that  $\xi_k > \zeta_k$ . In other words, we cannot find a point in  $\mathcal{W}$  whose entries are all bigger than  $\xi$ 's. The collection of all positively extreme points in  $\mathcal{W}$  will be denoted as  $\text{pe}(\mathcal{W})$ .

**Example 3.** If  $\mathcal{W} = \{\xi \in \mathbb{R}^{2T} : \max_i a_i |\xi_i| \leq \mu\}$  then  $\text{pe}(\mathcal{W})$  contains only the point  $(\frac{\mu}{a_1}, \dots, \frac{\mu}{a_{2T}})$ .

**Example 4.** If  $\mathcal{W} = \{\xi \in \mathbb{R}^{2T} : \sum_i a_i |\xi_i| \leq \mu\}$ ,  $\text{pe}(\mathcal{W})$  contains all points  $\xi$  such that  $\xi_i \geq 0$  and  $\sum_i a_i \xi_i = \mu$ . In particular,  $\text{pe}(\mathcal{W})$  is infinite.

**Theorem 1.** Let  $\mathcal{W}$  be any bounded closed subset of  $\mathbb{R}^{2T}$ , and assume all functions  $w_e$  satisfy (5). The problem (RSPP) for  $\mathcal{W}$  is equivalent to the problem (RSPP) for  $\text{pe}(\mathcal{W})$ , i.e.,

$$\min_{\text{Path}_{s \rightarrow q}} \max_{\xi \in \mathcal{W}} \sum_{e \in \text{Path}_{s \rightarrow q}} w_e(\xi) = \min_{\text{Path}_{s \rightarrow q}} \max_{\xi \in \text{pe}(\mathcal{W})} \sum_{e \in \text{Path}_{s \rightarrow q}} w_e(\xi). \quad (6)$$

**Proof.** Take any path  $\text{Path}_{s \rightarrow q}$  from  $s$  to  $q$ , and let  $e_1, \dots, e_\ell$  be its edges. We show that  $\max_{\xi \in \mathcal{W}} \sum_{i=1}^\ell w_{e_i}(\xi) = \max_{\xi \in \text{pe}(\mathcal{W})} \sum_{i=1}^\ell w_{e_i}(\xi)$ . Take some  $\zeta \in \mathcal{W}$ . We claim that there exists a point  $\xi \in \text{pe}(\mathcal{W})$  such that  $\zeta_i \leq \xi_i$  for all  $i$ . Indeed, this is true because the set  $\mathcal{W} \cap \{\xi : \zeta_i \geq \xi_i\}$  is also bounded and closed, hence it has a positively-extreme point, which must be in  $\text{pe}(\mathcal{W})$  by definition. In particular, we conclude by (5) that

$$\sum_{i=1}^\ell w_{e_i}(\zeta) \leq \sum_{i=1}^\ell w_{e_i}(\xi) \leq \max_{\xi \in \text{pe}(\mathcal{W})} \sum_{i=1}^\ell w_{e_i}(\xi).$$

Maximizing over  $\zeta \in \mathcal{W}$  completes the proof.  $\square$

We now examine a corollary of Theorem 1 that considers an estimate for the power and heat demand at a time  $t$ , denoted by  $P_0(t), H_0(t)$  respectively, and an estimation error that is bounded by variables  $\Delta P(t), \Delta H(t)$  respectively.

**Corollary 1.** Suppose that the set  $\mathcal{W}$  is given by:

$$\mathcal{W} = \left\{ (P(t), H(t))_{t=1}^T : \begin{aligned} &|P(t) - P_0(t)| \leq \Delta P(t), \\ &|H(t) - H_0(t)| \leq \Delta H(t) \end{aligned} \right\}, \quad (7)$$

The robust ED problem with uncertainty set  $\mathcal{W}$  is equivalent to the ED problem with demand  $P(t) = P_0(t) + \Delta P(t)$ ,  $H(t) = H_0(t) + \Delta H(t)$ . Thus, it can be solved in  $O(|\mathcal{E}|) = O(\max_{x,u} c(x, u) |X| T)$  time.

**Proof.** It suffices to show that (RSPP) for the set  $\mathcal{W}$  is equivalent to the shortest path problem with weights  $w_e(\xi)$  for  $\xi = (P_0(t) + \Delta P(t), H_0(t) + \Delta H(t))_{t=1}^T$ . This follows immediately from Theorem 1 and the fact that by definition,  $\text{pe}(\mathcal{W}) = (P_0(t) + \Delta P(t), H_0(t) + \Delta H(t))_{t=1}^T$ . Solving the shortest path problem in a DAG takes  $O(|\mathcal{E}|)$  time [29].  $\square$

The corollary above shows that the robust ED problem can be solved in a tractable manner if  $\mathcal{W}$  has the form (7), as it is equivalent to a shortest-path problem. However, in (7), the demand is merely assumed to be within given confidence intervals for each time step. This assumption might lead to mediocre results in practice - if the confidence intervals are taken too large, the solution may be over-conservative, and if they are taken too small, we do not account for unforeseen short demand spikes. A common way to deal with this problem is to use uncertainty sets which also specify the 1-norm, i.e. they budget the uncertainty over all time steps. This will be the focus of the next subsection.

Before moving forward, we want to return to Example 4. There,  $\text{pe}(\mathcal{W})$  was infinite, meaning that the problem  $\max_{\xi \in \text{pe}(\mathcal{W})} \sum w_e(\xi)$  is hard to solve, unless more assumptions are added. If we assume the functions  $w_e$  are convex in  $\xi$ , the maximized function is also convex, so the maximum is attained at an extreme point of the set  $\text{pe}(\mathcal{W})$  [46, Theorem 32.2]. The convexity of the functions  $w_e$  can be understood using the convexity of the functions  $C_{U,t}^P, C_{U,t}^H$ :

**Proposition 1.** All of the functions  $\{w_e\}_{e \in \mathcal{E}}$  are convex if and only if all of the functions  $C_{U,t}^P, C_{U,t}^H$  are convex

**Proof.** We fix an edge  $e$  from a node  $(t_1, x_1)$  to a node  $(t_2, x_2)$ , where  $x_1, x_2 \in \mathcal{X}$  are states of the turbine. Because there exists an edge between  $(t_1, x_1)$  and  $(t_2, x_2)$ , there exists a control action  $u_1 \in \mathcal{U}(x_1)$  such that  $f(x_1, u_1) = x_2$  and  $t_2 = t_1 + c(x_1, u_1)\Delta t$ . Recall that  $w_e$  was defined as a function of  $\xi = (P(t), H(t))_{t=1}^T$  using the following expression:

$$w_e(\xi) = C_{\text{MGT}}(x_1, u_1) + \sum_{t=t_1}^{t_2} [C_{U,t}^P(P(t) - P_{\text{MGT}}(x_1, u_1)) + C_{U,t}^H(H(t) - H_{\text{MGT}}(x_1, u_1))]$$

The result now follows from the fact that  $C_{\text{MGT}}(x_1, u_1)$ ,  $P_{\text{MGT}}(x_1, u_1)$  and  $H_{\text{MGT}}(x_1, u_1)$  are all constant with respect to  $\xi$ .  $\square$

For that reason, we make the following assumption:

**Assumption 1.** For every time  $t$ , the utility cost functions  $C_{U,t}^P, C_{U,t}^H$  are convex. Equivalently, the cost functions  $w_e$  are convex.

**Remark 2.** The convexity of  $C_{U,t}^P$  can be easily deduced for many cases. For example, the cost function implemented in European electricity markets is a linear function, in which the per-unit price is achieved by an optimization problem aggregating all the demands and generations in the network [52]. In other cases, service operators explicitly convexify this cost function [53]. Alternatively, utility operators put a fixed per-unit cost, as well as fixed costs and demand charges which only go into effect if the demand is positive [54]. In this case, if we cannot sell power back to the utility, then  $C_{U,t}^P(x_U^P) = A_t x_U^P + B_t$  for some possibly time-dependent parameters  $A_t, B_t$  and  $x_U^P \geq 0$ , and  $C_{U,t}^P(x_U^P) = \infty$  if  $x_U^P < 0$ . Thus,  $C_{U,t}^P$  is convex. If we instead consider the case in which there is only a fixed per-unit cost and a fixed cost, then  $C_{U,t}^P$  is affine and thus convex.

For heat, most consumers use a boiler to satisfy their heat demand, in which case one can model the heating cost with the price of natural gas. In that case, the cost function  $C_{U,t}^H$  is given by

$$C_{U,t}^H(x_U^H) = \begin{cases} Ax_U^H, & x_U^H \geq 0 \\ 0, & x_U^H \leq 0, \end{cases}$$

as excess heat can be exhausted with no extra cost. In particular,  $C_{U,t}^H$  is convex. See [6] for more details.

In any case, if either  $C_{U,t}^P$  or  $C_{U,t}^H$  is not convex, and Assumption 1 is needed, we approximate them by convex functions. We thus yield a suboptimal solution for (RSPP), whose quality depends on the approximation error of  $C_{U,t}^P, C_{U,t}^H$ .

Under Assumption 1, we can prove an analogue of Theorem 1 which relies on the notion of extreme points:

**Corollary 2.** Let  $\mathcal{W} \subseteq \mathbb{R}^2$  be bounded and closed, and assume  $w_e$  satisfies (5) and Assumption 1. The problem (RSPP) for  $\mathcal{W}$  is equivalent to the problem (RSPP) for  $\text{ext}(\text{pe}(\mathcal{W}))$ .

**Proof.** Fix any path  $\text{Path}_{s \rightarrow q}$  from  $s$  to  $q$ , and let  $e_1, \dots, e_\ell$  be its edges. We show that  $\max_{\xi \in \mathcal{W}} \sum_{i=1}^\ell w_{e_i}(\xi) = \max_{\xi \in \text{ext}(\text{pe}(\mathcal{W}))} \sum_{i=1}^\ell w_{e_i}(\xi)$ . First, by Theorem 1, we have that  $\max_{\xi \in \mathcal{W}} \sum_{i=1}^\ell w_{e_i}(\xi) = \max_{\xi \in \text{pe}(\mathcal{W})} \sum_{i=1}^\ell w_{e_i}(\xi)$ . Second, we note that  $\sum_{i=1}^\ell w_{e_i}(\xi)$  is a convex function in  $\xi$ , so by [46, Theorem 32.2], for any closed bounded set  $\mathcal{A}$  we have that

$$\max_{\xi \in \mathcal{A}} \sum_{i=1}^\ell w_{e_i}(\xi) = \max_{\xi \in \text{ext}(\mathcal{A})} \sum_{i=1}^\ell w_{e_i}(\xi).$$

Choosing  $\mathcal{A} = \text{pe}(\mathcal{W})$  completes the proof.  $\square$

**Example 5.** If  $\mathcal{W} = \{\xi \in \mathbb{R}^{2T} : \sum_i a_i |\xi_i| \leq \mu\}$ , then  $\text{ext}(\text{pe}(\mathcal{W})) = \{\xi^{(1)}, \dots, \xi^{(2T)}\}$ , where  $\xi_i^{(j)} = \frac{\mu}{a_i} \mathbb{1}_{\{i=j\}}$ .

### 3.2. Mixed $\mathcal{L}_1 \setminus \mathcal{L}_\infty$ uncertainty

For this subsection, we assume Assumption 1 holds. We want to consider an uncertainty set  $\mathcal{W}$  including both unforeseen short demand spikes as well as a constant bias from the estimate. A natural choice here is:

$$\mathcal{W} = \left\{ (P(t), H(t))_{t=1}^T : \begin{array}{l} |P(t) - P_0(t)| \leq \Delta P(t), \\ |H(t) - H_0(t)| \leq \Delta H(t) \\ \sum_{t=1}^T \left[ \frac{|P(t) - P_0(t)|}{\Delta P(t)} + \frac{|H(t) - H_0(t)|}{\Delta H(t)} \right] \leq \mu \end{array} \right\}.$$

However, it is possible to show that unless  $\frac{\mu}{2T} \ll 1$  or  $1 - \frac{\mu}{2T} \ll 1$ ,  $|\text{ext}(\text{pe}(\mathcal{W}))|$  is exponential in  $T$ . Thus, Corollary 2 will not yield a tractable optimization problem. Instead, we consider a different uncertainty set:

$$\mathcal{W} = \left\{ (P(t), H(t))_{t=1}^T : \begin{array}{l} P(t) = P_0(t) + \eta_1^P(t) + \eta_\infty^P(t), \\ H(t) = H_0(t) + \eta_1^H(t) + \eta_\infty^H(t), \\ \sum_{t=1}^T [|\delta_{P,t} \eta_1^P(t)| + |\delta_{H,t} \eta_1^H(t)|] \leq \mu_1, \\ |\eta_\infty^P(t)| \leq \Delta P(t), |\eta_\infty^H(t)| \leq \Delta H(t), \forall t \end{array} \right\}, \quad (8)$$

where  $\mu_1, \Delta P(t), \Delta H(t), \delta_{P,t}, \delta_{H,t} \geq 0$  are parameters. This uncertainty set will be called the “mixed  $\mathcal{L}_1/\mathcal{L}_\infty$  uncertainty set”. Intuitively, it dissects the uncertainty in the demand into two factors — the first,  $\eta_1^P(t), \eta_1^H(t)$ , corresponds to large-but-short unforeseen demand spikes, and the second,  $\eta_\infty^P(t), \eta_\infty^H(t)$ , corresponds to a small-but-long bias from the estimated demand,  $(P_0(t), H_0(t))_{t=1}^T$ . If  $\mu_1, \Delta P(t), \Delta H(t), \delta_{P,t}, \delta_{H,t}$  are tuned correctly, the uncertainty set can model both without being too conservative. Similarly to Example 4, the set  $\text{ext}(\text{pe}(\mathcal{W}))$  consists of  $2T$  elements,  $(\bar{P}(t) + \Delta P^{(i)}(t), \bar{H}_0(t))_{t=1}^T$  and  $(\bar{P}_0(t), \bar{H}_0(t) + \Delta H^{(i)}(t))_{t=1}^T$  for  $i = 1, \dots, T$ , where:

$$\bar{P}_0(t) = P_0(t) + \Delta P(t), \quad \bar{H}_0(t) = H_0(t) + \Delta H(t). \quad (9)$$

$$\Delta P^{(i)}(t) = \frac{\mu_1}{\delta_{P,t}} \mathbb{1}_{\{i=t\}}, \quad \Delta H^{(i)}(t) = \frac{\mu_1}{\delta_{H,t}} \mathbb{1}_{\{i=t\}}.$$

The demands  $\bar{P}_0(t)$  and  $\bar{H}_0(t)$  serve as a worst-case scenario if there are no demand spikes, similarly to Corollary 1. For each  $i = 1, 2, \dots, T$ , the terms  $\Delta P^{(i)}, \Delta H^{(i)}$  correspond to the highest possible demand spike at time  $i$ . In particular, for any  $i$ , the sum of these terms serves as

a possible worst-case scenario for the uncertainty set (8). Thus, the robust ED problem for  $\mathcal{W}$  is reduced to (RSPP) with  $2T$  possible demand profiles - 2 demand profiles for each time  $i$ , in which the power or heat demand spikes at time  $i$ , respectively. We want to use an augmented form of the shortest-path algorithm to solve this problem. In order to do so, we first reformulate it as a problem closer to the classical shortest-path problem.

For each edge  $e = (t_1, x_1) \rightarrow (t_2, x_2) \in \mathcal{E}$ , we consider the cost  $w_e$  for all  $2T$  possible scenarios. We first define  $W_{bias}(e)$  as  $w_e((\bar{P}_0(t), \bar{H}_0(t)))$ , which is the cost on the edge  $e$  corresponding to the worst-case spikeless demand, stemming only from the long-but-small bias in demand, which must be paid for each of the extreme  $2T$  scenarios, no matter when the spike occurs. We also let  $W_{spike}(e)$  be the highest possible additional cost stemming from unforeseen demand spikes, defined as

$$\max_{t_1 \leq k < t_2} \{w_e((\bar{P}_0(t) + \Delta P^{(k)}(t), \bar{H}_0(t))), \quad (10)$$

$$w_e((\bar{P}_0(t), \bar{H}_0(t) + \Delta H^{(k)}(t)))\} - W_{bias}(e),$$

That is,  $W_{spike}(e)$  is defined as the maximum possible cost of the edge  $e$  in any of the  $2T$  possible scenarios, minus  $W_{bias}(e)$ . Given a path  $\text{Path}_{s \rightarrow q}$  from  $s$  to  $q$ , the cost function  $\max_{\xi \in \mathcal{W}} \sum_{e \in \text{Path}_{s \rightarrow q}} w_e(\xi)$  is the sum of  $\sum_{e \in \text{Path}_{s \rightarrow q}} W_{bias}(e)$  and  $\max_{e \in \text{Path}_{s \rightarrow q}} W_{spike}(e)$ . Indeed, if the demand profile is equal to  $(\bar{P}_0(t) + \Delta P^{(k)}(t), \bar{H}_0(t))_{t=1}^T$  or to  $(\bar{P}_0(t), \bar{H}_0(t) + \Delta H^{(k)}(t))_{t=1}^T$ , meaning there is a spike in demand at time  $k$ , then all edges corresponding to transitions outside time  $k$  only have the “bias” cost, while the single edge corresponding to a transition at time  $k$  has a  $W_{bias} + W_{spike}$ . Moreover, given any edge  $e = (t_1, x_1) \rightarrow (t_2, x_2) \in \mathcal{E}$ , there is at least one  $k$  for which this edge has an additional cost equal to  $W_{spike}$ . Thus, the optimization problem becomes:

$$\min \sum_{e \in \text{Path}_{s \rightarrow q}} W_{bias}(e) + \max_{e \in \text{Path}_{s \rightarrow q}} W_{spike}(e) \quad (11)$$

s.t.  $\text{Path}_{s \rightarrow q} \in \text{PATH}_{s \rightarrow q}(\mathcal{G})$ .

We would like to consider an algorithm for solving the problem (RSPP) in this case. A key idea that will be used is to consider the graph  $\mathcal{G}$  with a different set of weights. For each number  $\alpha \in \mathbb{R}$ , we define the  $\alpha$ -restricted graph  $\mathcal{G}_\alpha$  as a weighted graph  $(\mathcal{V}, \mathcal{E}, \omega_\alpha)$ , where  $\mathcal{G} = (\mathcal{V}, \mathcal{E})$  and  $\omega_\alpha(e) = \begin{cases} W_{bias}(e) & W_{spike}(e) \leq \alpha \\ \infty & W_{spike}(e) > \alpha. \end{cases}$  We present the following algorithm for solving the problem. First, we compute all parameters as in (9), and define  $W_{bias}, W_{spike}$  as above. Second, we define an array of thresholds called Thresh. For each threshold  $\alpha \in \text{Thresh}$ , we solve the classical shortest-path problem on the weighted graph  $\mathcal{G}_\alpha$ . We let  $V_{\text{path}}(\alpha)$  be this shortest path on  $\mathcal{G}_\alpha$ , and let  $V_{\text{cost}}(\alpha)$  as the total cost of this path in the problem (11). We then choose the return the path  $V_{\text{path}}(\alpha)$  for which  $V_{\text{cost}}(\alpha)$  is minimal over all thresholds  $\alpha$ . We show that choosing the set of thresholds as  $\{W_{spike}(e)\}_{e \in \mathcal{E}}$  guarantees that we achieve an optimal solution of (11).

**Theorem 2.** Algorithm 1 solves (RSPP) for the uncertainty set  $\mathcal{W}$  of the form (8), with computational complexity  $O(|\mathcal{E}|^2)$ .

**Proof.** Let  $\text{Path}_{s \rightarrow q}^*$  be the optimal solution of (RSPP). By optimality, for any other path  $\text{Path}_{s \rightarrow q}$  at least one of the following holds:

$$\sum_{e \in \text{Path}_{s \rightarrow q}^*} W_{bias}(e) \leq \sum_{e \in \text{Path}_{s \rightarrow q}} W_{bias}(e), \quad (12)$$

$$\max_{e \in \text{Path}_{s \rightarrow q}^*} W_{spike}(e) \leq \max_{e \in \text{Path}_{s \rightarrow q}} W_{spike}(e), \quad (13)$$

where if at least one holds with equality, then both inequalities hold. Consider the graph  $\mathcal{G}_\alpha$  for  $\alpha = \max_{e \in \text{Path}_{s \rightarrow q}^*} W_{spike}(e)$ . For this graph, if a path  $\text{Path}_{s \rightarrow q}$  satisfies the inequality (13), it does so with equality. Thus,

**Algorithm 1** Optimal Economic Dispatch for Mixed  $\mathcal{L}_1/\mathcal{L}_\infty$  Uncertainty

**Input:** An uncertainty set  $\mathcal{W}$  of the form (8).

**Output:** An optimal solution to the corresponding robust economic dispatch problem.

- 1: Define  $\bar{P}_0(t), \bar{H}_0(t), \Delta P^{(i)}(t), \Delta H^{(i)}(t)$  as in (9).
- 2: Define four arrays  $W_{bias}, W_{spike}, V_{cost}, V_{path}$ .
- 3: **for** each edge  $e$  in the graph **do**
- 4:   Define  $W_{bias}(e) = w_e((\bar{P}_0(t), \bar{H}_0(t))_{t=1}^T)$ .
- 5:   Define  $W_{spike}(e)$  as in (10).
- 6: **end for**
- 7: Define the array  $\text{Thresh} = W_{spike}$ .
- 8: **for**  $\alpha \in \text{Thresh}$  **do**
- 9:   Solve the shortest-path problem from  $s$  to  $q$  for  $\mathcal{G}_\alpha$ . Let  $\text{Path}_{s \rightarrow q}$  the optimal path. If there is a tie, favor the path with the lower maximal  $W_{spike}$ .
- 10:   Define  $V_{path}(\alpha) = \text{Path}_{s \rightarrow q}$ .
- 11:   Define  $V_{cost}(\alpha) = \sum_{e \in \text{Path}_{s \rightarrow q}} W_{bias}(e) + \max_{e \in \text{Path}_{s \rightarrow q}} W_{spike}(e)$ , the cost of the path  $\text{Path}_{s \rightarrow q}$  for the problem (11).
- 12: **end for**
- 13: Find  $\gamma = \arg \min_\beta V_{cost}(\beta)$ .
- 14: **return:**  $V_{cost}(\gamma), V_{path}(\gamma)$ .

it must satisfy (12), meaning that  $\text{Path}^*$  is the shortest path from  $s$  to  $q$  in  $\mathcal{G}_\alpha$ . By the tie break rule and conditions (12), (13), we conclude that  $V_{\text{path}}(\alpha) = \text{Path}^*$ . Moreover, for any path  $V_{\text{path}}(\beta)$ , we have:

$$V_{\text{cost}}(\beta) = \sum_{e \in V_{\text{path}}(\beta)} W_{bias}(e) + \max_{e \in V_{\text{path}}(\beta)} W_{spike}(e)$$

Thus, by optimality of  $\text{Path}^*$ ,  $\alpha = \arg \min_\beta V_{\text{cost}}(\beta)$ , and the returned path is  $\text{Path}^*$ . This proves the correctness of the algorithm. As for the time complexity, the parts outside the for-loop on  $\alpha$  take  $O(|\mathcal{E}|)$  time. Inside the for-loop, we build the DAG  $\mathcal{G}_\alpha$ , which takes  $O(|\mathcal{E}|)$  time, and solve the shortest-path problem on it, which also takes  $O(|\mathcal{E}|)$  time. The for-loop has  $O(|\mathcal{E}|)$  iterations, so get a time complexity of  $O(|\mathcal{E}|^2)$ .  $\square$

**Remark 3.** The complexity of graph-based algorithms is traditionally written in terms of the number of vertices  $|\mathcal{V}|$  in the graph, or the number of edges  $|\mathcal{E}|$  in the graph. The complexity estimate of Theorem 2 follows this norm, writing the complexity as  $O(|\mathcal{E}|^2)$ . However, we would like to connect this complexity estimate to the turbine model.

To do so, for any  $x \in \mathcal{X}$ , we let  $\rho(x) = |\mathcal{U}(x)|$  be the number of possible control actions at  $x$ . We also let  $\rho_{\mathcal{X}} = \frac{1}{|\mathcal{X}|} \sum_{x \in \mathcal{X}} \rho(x)$  be the average number of control actions at a state. If the time horizon  $T$  is long enough, then  $|\mathcal{E}| = O(T|\mathcal{X}|\rho_{\mathcal{X}})$ . For example, this happens if  $T$  is at least twice as long as the longest transition,  $\max_{x,u} c(x,u)$ . In that case, the complexity estimate is  $O(\mathcal{E}^2) = O(T^2|\mathcal{X}|^2\rho_{\mathcal{X}}^2)$ . This estimate will also be helpful later, when we present more efficient algorithms with complexity  $O(|\mathcal{E}|) = O(T|\mathcal{X}|\rho_{\mathcal{X}})$ .

**Remark 4.** The complexity bound  $O(|\mathcal{E}|^2)$  can sometimes be too high for real-world economic dispatch problems, in which the graph  $\mathcal{G}$  can have more than a million edges [6]. Instead, we note that if  $\delta_{P,t}, \delta_{H,t}$  defined in (8) do not change too often, the array Thresh contains many repetitions. If Thresh contains  $L \leq |\mathcal{E}|$  different elements, then the computational complexity of the algorithm is  $O(|\mathcal{E}|L)$ . We denote the number of different values that  $\delta_{P,t}, \delta_{H,t}$  take for  $t = 1, \dots, T$  as  $n_P, n_H$  respectively. It is easy to see that if  $T \gg \max_{x,u} c(x,u)$ , so that each possible transition appears about the same number of times, then  $L$  scales linearly with  $n_P + n_H$ . Thus, we get that  $L = O\left(\frac{|\mathcal{E}|}{T}(n_P + n_H)\right)$ .

Therefore, we get an algorithm whose time complexity  $O(|\mathcal{E}|L) = O\left(\frac{|\mathcal{E}|^2}{T}(n_P + n_H)\right)$  grows linearly with the time horizon  $T$ , as for a fixed state-space representation,  $|\mathcal{E}| = O(T)$  holds.

Algorithm 1, together with Remark 4, give a linear-time algorithm if most  $\delta_{P,t}, \delta_{H,t}$  have the same value. If this is not the case, we can give a linear-time algorithm that achieves an approximation of the optimal solution. Namely, we prove:

**Lemma 1.** Consider the problem (RSPP) for the uncertainty set  $\mathcal{W}$  of the form (8), and let  $\text{Path}_{s \rightarrow q}^*$  be the optimal solution,  $\alpha = \max_{e \in \text{Path}_{s \rightarrow q}^*} W_{\text{spike}}(e)$ , and let  $\beta \geq \alpha$  be any number. Denote  $\text{Path}_{s \rightarrow q}^\beta$  as the shortest path from  $s$  to  $q$  in  $\mathcal{G}_\beta$ . If:

$$V^* = \sum_{e \in \text{Path}_{s \rightarrow q}^*} W_{\text{bias}}(e) + \max_{e \in \text{Path}_{s \rightarrow q}^*} W_{\text{spike}}(e)$$

$$V^\beta = \sum_{e \in \text{Path}_{s \rightarrow q}^\beta} W_{\text{bias}}(e) + \max_{e \in \text{Path}_{s \rightarrow q}^\beta} W_{\text{spike}}(e),$$

$$\text{then } V^* \leq V^\beta \leq \min\{V^* + \beta - \alpha, \frac{\beta}{\alpha} V^*\}.$$

**Proof.** It suffices to show that the right side of the inequality holds. First, as  $\beta \geq \alpha$ , the path  $\text{Path}_{s \rightarrow q}^*$  has a finite cost in the graph  $\mathcal{G}_\beta$ , equal to its cost in  $\mathcal{G}$ . Thus, we find that:

$$\sum_{e \in \text{Path}_{s \rightarrow q}^\beta} W_{\text{bias}}(e) \leq \sum_{e \in \text{Path}_{s \rightarrow q}^*} W_{\text{bias}}(e). \quad (14)$$

Moreover,

$$\max_{e \in \text{Path}_{s \rightarrow q}^\beta} W_{\text{spike}}(e) \leq \beta = \alpha + \epsilon \leq \max_{e \in \text{Path}_{s \rightarrow q}^*} W_{\text{spike}}(e) + \epsilon. \quad (15)$$

Summing (14) and (15) gives  $V^\beta \leq V^* + \epsilon$ . Moreover, as  $\tau \geq 1$ , we have,

$$\sum_{e \in \text{Path}_{s \rightarrow q}^\beta} W_{\text{bias}}(e) \leq \tau \sum_{e \in \text{Path}_{s \rightarrow q}^*} W_{\text{bias}}(e), \quad (16)$$

and

$$\max_{e \in \text{Path}_{s \rightarrow q}^\beta} W_{\text{spike}}(e) \leq \beta = \tau \alpha \leq \tau \max_{e \in \text{Path}_{s \rightarrow q}^*} W_{\text{spike}}(e). \quad (17)$$

Summing (16) and (17) gives  $V^\beta \leq (1 + \mu)V^*$ .  $\square$

Lemma 1 can be used to prescribe linear-time algorithms approximating the optimal solution of (RSPP) for the uncertainty set (8):

**Theorem 3.** Consider Algorithm 1 and take any  $\epsilon > 0$ . Suppose that we change step 7 and define

$$\text{Thresh} = \left\{ \min_{e \in \mathcal{E}} W_{\text{spike}}(e), \min_{e \in \mathcal{E}} W_{\text{spike}}(e) + \epsilon, \min_{e \in \mathcal{E}} W_{\text{spike}}(e) + 2\epsilon, \dots, \max_{e \in \mathcal{E}} W_{\text{spike}}(e) \right\}.$$

Let  $V^{*,\epsilon}$  be the value provided by this modified algorithm, and let  $V^*$  be the optimal value of (RSPP) for the uncertainty set  $\mathcal{W}$  of the form (8). Then  $V^* \leq V^{*,\epsilon} \leq V^* + \epsilon$ . Moreover, the computational complexity of the modified algorithm is  $O(|\mathcal{E}| \cdot \left\lceil \frac{\max_{e \in \mathcal{E}} W_{\text{spike}}(e) - \min_{e \in \mathcal{E}} W_{\text{spike}}(e)}{\epsilon} \right\rceil + 1)$ .

**Proof.** Suppose that  $\alpha$  is  $\max_e W_{\text{spike}}(e)$ , where the maximum is taken over the optimal solution to (RSPP). By construction, there exists some  $\beta \in \text{Thresh}$  such that  $\beta \leq \alpha$  and  $\epsilon \leq \beta - \alpha$ . By Lemma 1, we conclude that  $V^* \leq V_{\text{cost}}(\beta) \leq V^* + \epsilon$ . By step 13, we have that  $V^{*,\epsilon} \leq V_{\text{cost}}(\beta) \leq V^* + \epsilon$ . The inequality  $V^* \leq V^{*,\epsilon}$  is clear, as  $V^*$  is the optimal cost over all possible trajectories. Thus  $V^* \leq V^{*,\epsilon} \leq V^* + \epsilon$ . As for the time complexity, the same argument as in the proof of Theorem 2 shows that the time complexity is  $O(|\mathcal{E}|N)$ , where  $N$  is the number of points in Thresh. It can easily be seen that  $N = \left\lceil \frac{\max_{e \in \mathcal{E}} W_{\text{spike}}(e) - \min_{e \in \mathcal{E}} W_{\text{spike}}(e)}{\epsilon} \right\rceil + 1$ , which gives the desired complexity bound. This completes the proof.  $\square$

Similarly, we prove:




Fig. 2. Normed ball in  $\mathbb{R}^2$ . The black set is an  $\ell^\infty$ -normed ball, and the green set is an  $\ell^1$ -normed ball. The yellow set is a larger  $\ell^\infty$ -normed ball, which is the analogue of (7). The blue set is the Minkowski sum of the black and purple sets, which is the analogue of (8). The blue set is a subset of the yellow set which does not include points in which both entries are large in absolute value.

**Theorem 4.** Consider Algorithm 1 and take any  $\mu > 0$ . Suppose that we change step 7 and define

$$\text{Thresh} = \left\{ \min_{e \in \mathcal{E}} W_{\text{spike}}(e), (1 + \mu) \min_{e \in \mathcal{E}} W_{\text{spike}}(e), (1 + \mu)^2 \min_{e \in \mathcal{E}} W_{\text{spike}}(e), \dots, \max_{e \in \mathcal{E}} W_{\text{spike}}(e) \right\}.$$

Let  $V^{*,\mu}$  be the value provided by this modified algorithm, and let  $V^*$  be the optimal value of (RSPP) for the uncertainty set  $\mathcal{W}$  of the form (8). Then  $V^* \leq V^{*,\mu} \leq (1 + \mu)V^*$ . Moreover, the computational complexity of the modified algorithm is  $O(|\mathcal{E}| \cdot \left\lceil \frac{\log \max_{e \in \mathcal{E}} W_{\text{spike}}(e) - \log \min_{e \in \mathcal{E}} W_{\text{spike}}(e)}{\log(1 + \mu)} \right\rceil + 1)$ .

**Proof.** As before, let  $\alpha = \max_e W_{\text{spike}}(e)$ , where the maximum is taken over the optimal solution to (RSPP). By construction, there exists some  $\beta \in \text{Thresh}$  such that  $1 \leq \frac{\beta}{\alpha} \leq 1 + \mu$ . By Lemma 1, we conclude that  $V^* \leq V_{\text{cost}}(\beta) \leq (1 + \mu)V^*$ . By step 13, we have that  $V^{*,\mu} \leq V_{\text{cost}}(\beta) \leq (1 + \mu)V^*$ . Together with  $V^* \leq V^{*,\mu}$ , stemming from optimality, we conclude that  $V^* \leq V^{*,\mu} \leq (1 + \mu)V^*$ . As for the time complexity, the same argument as in the proof of Theorem 2 shows that the time complexity is  $O(|\mathcal{E}|N)$ , where  $N$  is the number of points in Thresh. It can easily be seen that  $N = \left\lceil \frac{\log \max_{e \in \mathcal{E}} W_{\text{spike}}(e) - \log \min_{e \in \mathcal{E}} W_{\text{spike}}(e)}{\log(1 + \mu)} \right\rceil + 1$ , which gives the desired complexity bound.  $\square$

### 3.3. Discussion about uncertainty sets and algorithms

In the previous sections, we presented two possible choices for the uncertainty set. The first one, (7), can be understood as a norm ball of a weighed  $\ell^\infty$ -norm, centered around the point  $(P_0(t), H_0(t))$ . Indeed, the condition in (7) can be restated as  $\frac{1}{\Delta P(t)} |P(t) - P_0(t)| \leq 1$  and  $\frac{1}{\Delta H(t)} |H(t) - H_0(t)| \leq 1$ , which define a norm ball of radius 1 around the point  $(P_0(t), H_0(t))$ . The second choice of uncertainty set, (8), can be similarly seen as a Minkowski sum of two norm balls centered around  $(P_0(t), H_0(t))$ , the first being a weighted  $\ell^1$ -norm, and the second being a weighted  $\ell^\infty$ -norm.

The tunable parameters  $\Delta P(t), \Delta H(t), \delta_{P,t}, \delta_{H,t}, \mu_1$  are used to determine the size and exact shape of these uncertainty set. Fig. 2 demonstrates the  $\ell^1$ -normed ball,  $\ell^\infty$ -normed ball, and their Minkowski sum in  $\mathbb{R}^2$ . It is seen in Fig. 2 that with correct scaling, the Minkowski sum is a subset of an  $\ell^\infty$ -normed ball which does not contain points in which all entries are “large” in absolute value, but still contains points in which a subset of the entries is large.



We now return to the uncertainty sets (7) and (8). With correct tuning, the set (8) is a subset of (7) which removes scenarios in which the realization of the demand uncertainty is “large” in absolute value for all times, but includes scenarios in which the realization of the demand uncertainty is “large” only for a subset of times. When solving (RSPP), smaller uncertainty sets allow us to reduce our conservatism, and hence improve our performance, assuming the uncertainty set contains the (unknown) true demand. This will become evident in the next section, which will test the prescribed algorithm in a case study.

To conclude, the mixed uncertainty set (8) considers more realistic scenarios, in which the demand does not simultaneously peak at all time steps. In practice, if the nominal demand  $(P_0(t), H_0(t))_{t=1}^T$  is achieved from a load prediction algorithm, e.g. one appearing in [34–37], the parameters  $\Delta P(t), \Delta H(t), \delta_{P,t}, \delta_{H,t}, \mu_1$  are fitted by looking at the deviation of the algorithm. Some prediction algorithms report their expected standard deviation, while for others, we can look at the accuracy of the algorithm in the past. It might seem as if we return to the previous problem, where parameter inaccuracy jeopardized the performance of the algorithm, there are evidence that the robust algorithms are much less vulnerable to such parameter inaccuracies [43].

Before moving on to the case studies illustrating the performance of the algorithms, we wish to elaborate a bit more on the complexity of the algorithms displayed above in terms of the discretization of the turbine:

**Remark 5.** Corollary 1 and Theorems 2–4 prescribe complexity bounds on the algorithms presented in this section. The complexity bound is stated in terms of the number of edge  $|\mathcal{E}|$  in the graph, which is the custom for graph-based algorithms in computer science [29]. However, we would like to understand it in terms of the discretization of the turbine.

The number of vertices  $|\mathcal{V}|$  in the graph is equal to  $T|\mathcal{X}|$ , where  $T$  is the horizon of the problem and  $\mathcal{X}$  is the discrete state-space of the turbine. The relationship between the number of vertices and the number of edges is a bit more complex. Generally, we know that  $|\mathcal{V}| \leq |\mathcal{E}| \leq \|\mathcal{V}\|^2$ , as any vertex is connected to at least one other vertex, but no more than  $\|\mathcal{V}\|$  other vertices. A more precise relationship can be achieved by considering the dynamics of the discretized model. Namely, the number of edges is smaller than  $T \sum_{x \in \mathcal{X}} |\mathcal{U}(x)|$ , and both are roughly equal if  $T$  is much larger than most transition lengths  $c(x, u)$ . If we assume that the number of control actions in each state is bounded between  $\mathcal{U}_{\min}$  and  $\mathcal{U}_{\max}$ , then  $T\mathcal{U}_{\min}|\mathcal{X}| \leq |\mathcal{E}| \leq T\mathcal{U}_{\max}|\mathcal{X}|$ . In that case, linear-time and quadratic-time algorithms in  $|\mathcal{E}|$  are also linear-time and quadratic-time algorithms in  $|\mathcal{X}|$ , respectively.

## 4. Case studies

### 4.1. Modeling and pricing

We demonstrate the benefit of the presented algorithm in the economic dispatch of an MGT for CHP operation, whose cost functions are inspired by a discretized version of the Capstone C65 turbine [7]. The engine unit consists of a single stage centrifugal compressor, a can-type combustor, a single stage turbine, a recuperator and a separate heat recovery unit. In order to accommodate the changing ratio between power and heat generation demand, the recuperator is equipped with a controllable valve which alters the amount of exhaust gasses bypassing the heat exchanger. The cycle's schematic is presented in Fig. 3.

In order to optimize the MGT cycle during its operation, two input parameters (shaft speed and recuperator bypass valve position) are selected and simulated to yield a number of solution states (electrical power and heat output that prescribes fuel mass flow). The discrete state space consists of 1501 states (1500 active states and one ‘off’ state), corresponding to 30 different engine shaft speeds (38.4–96 krpm) and 50 bypass valve positions (0–45%). The thermodynamic performance of the MGT is characterized in electrical power and heat output domains




Fig. 3. Engine schematic cycle.

ranging between 5–65 kWel and 27–216 kW respectively; see Fig. 4(a)–(c). The lowest heat to power output ratio varies between 1.7–3.3 for 0–45% bypassing conditions.

We adopt the edge weight scheme appearing in [6] and determine the cost of an edge in the graph  $\mathcal{G}$  as follows: for an edge between a state  $x(t_1)$  and a state  $x(t_2)$ , the power generation is defined as the average power  $\frac{x(t_1) + x(t_2)}{2}$  times the transition time  $t_2 - t_1$ . The transition time is defined as 15 s if we do not increase the engine rpm, and as 30 s if we increase it by one step. The heat generation, fuel consumption and demand on the edge are defined similarly. The cost of the edge is now defined as the sum of the fuel cost, plus the cost of buying power and heat from the utility, while ensuring the power- and heat-balance equations are satisfied. In addition, there is a cost associated with the start-up and shut-down of the unit.

The cost of a gas turbine engine is roughly \$75,000. Thus, assuming a low cycle fatigue life of 10,000 cycles [55], we estimate the cost of shutdown and startup as \$3.75 each. We assume the MGT is offline throughout start-up (lasting 6 mins) and shut-down (lasting 3 mins) sequences, so all power and heat must be purchased from the utility.

The dispatch problem is considered for a residential building of multiple apartments. The demand profile of each apartment stems from the data published by the U.S. Department of Energy for the entire year of 2004 [56–58]. Within this database, we only consider the residential buildings internally specified as “Residential High”.<sup>3</sup> In order to decide how many apartments benefit from the same MGT, the demand is scaled such that 95% of the time, the turbine’s electrical capacity is 80% of the consumer demand. This roughly corresponds to the needs of 9.3 apartments for our 65 kWel turbine capacity.

For the cost of energy supplied from the utility, the price of electricity was determined according to data from PSEG Long Island New York [59], similar to [6]. In particular, the price of electricity is different between peak hours<sup>4</sup> and off-peak hours, as well as between winter days<sup>5</sup> and summer days.<sup>6</sup> See [6, Table 2,3] for residential buildings for more information. In addition to electricity, the energy source for heat/chill can also be obtained from the utility to achieve energy balance between the demand and supply. As most consumers use a boiler to satisfy their heat demand, we model the heating cost with the price of natural gas — as shown in Eq. 24 in Ref. [6]. As for the cost of energy supplied by the MGT, the natural gas is the only consumable. The price of natural gas was taken to be \$18.42 per thousand cubic feet,<sup>7</sup> which was the residential price of natural gas in August 2020 [60]. If the MGT produces excess electricity beyond that

<sup>3</sup> The full name of the file is USA\_NY\_New.York-Central.Park.725033\_TMY3\_HIGH.csv.

<sup>4</sup> These are the hours between 10 AM and 8 PM.

<sup>5</sup> These are days between October 1st and May 31st.

<sup>6</sup> These are days between June 1st and September 30th.

<sup>7</sup> Or equivalently, about 95 cents per kilogram.




Fig. 4. Solution grid over the states of the gas turbine model.

of the local demand, the output is sold to the utility at the same tariff rate as the retail cost.

In our previous work [6], it was shown that the solution to the ED problem under deterministic and known demand profiles leads to four fundamental modes of operation for the MGT: electricity, heat, maintenance-cost and profit driven. Electricity and heat driven modes are dependent on the customer demand profiles in which peak electricity and peak heat requests vary through yearly seasons and day hours. Maintenance-cost driven behavior is geared towards minimizing losses associated with low cycle fatigue cost for each shutdown and startup, along with fuel burned during these sequences. This operational state is manifested by running the MGT at a minimal electricity and heat production level (typically during the off-peak tariff period) despite the fulfillment of the demand from the utility appears to be more economical. Finally, in the profit driven state, the MGT operates at an electricity production level significantly beyond the consumer demand, selling all the excess electricity to the grid.

#### 4.2. Algorithms and running time

We treat the year 2004 as real time for assessing the performance of each algorithm. The dispatch problem is considered for a horizon of 24 h, dividing it to  $T = 5760$  intervals, each 15 s long. Although we have the ground-truth demand for each day, it is not available when solving the economic dispatch problem in practice, since we cannot predict the “future” accurately. Instead, we must use an estimate of the demand. For a given day, we use the ground-truth demand data from the previous two weeks (which are indeed available in practice while solving the ED problem) to compute an estimate of the demand for that day. For each time of day  $t$ , we compute the sample mean  $\mu_P(t)$ ,  $\mu_H(t)$  and the standard deviation  $\sigma_P(t)$ ,  $\sigma_H(t)$  of both power and heat demand from the preceding two weeks.

The performance of three algorithms are compared. Firstly, the ED algorithm from [6] that does not account for demand uncertainty is applied to the forecasted mean demand ( $\mu_P(t)$ ,  $\mu_H(t)$ ) - we term this as the *nominal* algorithm. Moreover, the two robust ED algorithms presented in this work are considered. Their uncertainty sets use the standard deviation  $\sigma_P(t)$ ,  $\sigma_H(t)$  of the power and heat demands, in addition to the forecasted mean demand.

The first uncertainty set we choose is of the form (7) with  $P_0(t) = \mu_P(t)$ ,  $H_0(t) = \mu_H(t)$  and  $\Delta P(t) = \alpha_{L_\infty} \sigma_P(t)$ ,  $\Delta H(t) = \alpha_{L_\infty} \sigma_H(t)$  for some parameter  $\alpha_{L_\infty} > 0$ . The tuning parameter  $\alpha_{L_\infty}$  represents the trade-off between conservatism and accuracy. If  $\alpha_{L_\infty}$  grows larger, the probability that the ground-truth demand is inside the uncertainty set becomes bigger. However, this also implies the algorithm considers greater likelihood for outlier events associated with worst-case demand profiles; hence the solution becomes more conservative. In this study,  $\alpha_{L_\infty}$  is selected to be 0.13. The second uncertainty set we choose is of the form (8) where  $P_0(t) = \mu_P(t)$ ,  $H_0(t) = \mu_H(t)$ ,  $\Delta P(t) = \alpha_{\text{Mixed},1} \sigma_P(t)$ ,  $\Delta H(t) = \alpha_{\text{Mixed},1} \sigma_H(t)$ ,  $\delta_{P,t} = \frac{1}{\sigma_P(t)}$ ,  $\delta_{H,t} = \frac{1}{\sigma_H(t)}$ , and  $\mu_1 = \alpha_{\text{Mixed},2}$ . The parameters  $\alpha_{\text{Mixed},1}$ ,  $\alpha_{\text{Mixed},2}$  determine the size of the

uncertainty set and are tunable. Here, we chose  $\alpha_{\text{Mixed},1} = 0.03$  and  $\alpha_{\text{Mixed},2} = 40$ .

All the algorithms were computed on a Dell Latitude 7400 computer with an Intel Core i5-8365U processor. The nominal algorithm utilizes the shortest path formulation presented in [6]. For the first robust ED algorithm choice, Corollary 1 shows that a single application of the shortest path algorithm suffices as well. Both the nominal algorithm and the first robust algorithm use the same underlying combinatorial solution provided by the MATLAB internal shortest path solver, meaning they have nearly identical running times. For a total of 1500 discretization level combinations, building the graph and finding the shortest path takes about 2 min. For the second robust ED algorithm choice, we must apply Algorithm 1. As the number of edges in the underlying graph is in the millions, the application of Algorithm 1 would require running the shortest path algorithm on roughly 10 million different graphs. We instead use the approximate version described in Theorem 3, where  $\epsilon$  is chosen such that exactly  $N = 30$  applications of the shortest path problems are performed. Even then, the runtime is significantly longer, about 7 min. However, it is still considered fast enough to be applicable in real-world systems. (Note that these runtimes can vary for different choices of the turbine discretizations.)

In addition to these three cases that forecast the demand, in order to contrast the performance of the algorithms with the global optimum, the shortest-path algorithm is applied to the ground-truth demand, which cannot be used in practice, as this quantity is unknown at the time of scheduling. Since this case produces the best possible schedule, we present it as the “benchmark” in all solutions.

#### 4.3. Schedules and associated costs for residential buildings

In order to demonstrate the performance of the algorithms, a few exemplary days were analyzed considering their known two week demand histories: one winter day (February 5th), one spring day (March 24th), one summer day (June 28th), and one autumn day (September 19th). We note that the winter electricity tariff is used in the winter and spring days, whereas the summer electricity tariff is used in the summer and autumn days. For each day, the two robust algorithms (with demand uncertainty) and the nominal algorithm (without demand uncertainty) are evaluated based on the forecasted demand, and compared to the benchmark schedule stemming from known ground truth demand. Figs. 5–8 present the resulting MGT electricity and heat production schedules of the 3 algorithms and contrasts it with the benchmark case utilizing ground-truth demand, which is also charted separately. The blue bands around the power and heat schedules indicate the forecasted demands with the standard deviations utilized in the uncertainty sets of the robust algorithms. In order to clarify the actual impact on the engine control parameters, spool speed and bypass valve position are separately charted for each algorithm. The schedules are computed for  $T = 5760$  intervals, each 15 s long.

In the winter day of February 5th, Fig. 5, it can be seen that all four algorithms keep the MGT spool speed constant at its minimum operational value at almost all times, yielding the smallest amount

of local electricity production, consistently below the power demand, which is predominantly met by purchase from the utility. However, the differences in schedules arise from changes in bypass valve schedule and the associated MGT heat production. Thus, the solution seems to be heat demand driven. The first robust algorithm gives the closest results to the benchmark case, followed by the second robust algorithm, and the worst case is the nominal algorithm absent of uncertainty.

Similarly, in the spring day of March 24th, Fig. 6, all four algorithms keep the MGT spool speed constant at its minimum operational value at almost all times, significantly below the power demand, which is met by purchase from the utility. The second robust algorithm produces the same schedule as the nominal algorithm, but the first robust algorithm and the benchmark induce different schedules by choosing different trajectories for the bypass valve. This suggests that the solution is heat driven also in this scenario. The first robust algorithms slightly outperforms the others, although the schedules produced by all three algorithms have similar associated costs.

In the summer day of June 28th, Fig. 7, the first robust algorithm and the nominal algorithm produce identical schedules, and the second robust algorithm produces almost the same schedule as the benchmark. All algorithms decide to start the day operational. In the morning hours of the day (0–10 AM), the MGT spool speed is near its minimum level and the electricity production is below the local demand. Moreover, the bypass valve is set to 0%, manifesting maintenance-cost driven behavior. At around 10 AM, the MGT spool speed increases to about 78krpm in order to satisfy the local demand. However, the electricity output of the turbine is not maximized, as the MGT does not reach its highest rpm. This appears to be an electricity demand driven operation, which lasts until around 19:00. From 20:00 until midnight, the first robust and the nominal algorithms decide to turn the turbine off, where as the second robust algorithm decides to keep it operating close to the minimum capacity. In fact, the second robust algorithm achieves a nearly identical schedule to the benchmark, with only a small change around 8–9 PM, and a difference in cost of less than 1 cent.

In the fall day of September 19th, see in Fig. 8, according to the benchmark case, the optimal schedule is to shut down the MGT for the entire day. This corresponds to a maintenance-cost driven solution, as it implies that the possible savings that could be achieved by turning on the turbine are negated by the low cycle fatigue cost associated with each startup and shutdown. Only the second robust algorithm manages to replicate this behavior. Both the first robust and the nominal algorithms turn on the turbine, and achieve an identical schedule, with a difference in cost of \$6.4.

Table 1 summarizes the daily scheduling cost of all cases, where the most favorable forecasting solution of that day is highlighted by italics. In each of the days, both robust algorithms perform at least as well as the nominal algorithm. Moreover, the first robust algorithm outperformed the nominal algorithm for all days with winter electricity tariff, with savings up to \$0.89 per day. The second robust algorithm outperformed the nominal algorithm for all days with summer electricity tariff, with savings up to \$6.37 per day. In fact, the second robust algorithm has exactly the same scheduling cost as the benchmark case in these days, meaning it successfully finds the global minimum.

We can consider an alternative performance metric for the robust algorithms. It is clear that the benchmark cost is the optimum over all possible schedules. The nominal algorithm is an uncertainty-agnostic algorithm which represents the baseline from which we begin, in an effort to reduce the cost. The margin in cost between the nominal algorithm and the benchmark represents the potential benefit that any robust algorithm can offer. In Table 1, indicated in parentheses, we calculate the reduction of excess cost as a percentage of this margin, such that 100% and 0% reduction, implies that the robust algorithm performs identically to the benchmark and nominal cases respectively. For the four days considered, the first robust algorithm has an average reduction in excess cost of about 4%, and the second robust algorithm




Fig. 5. Schedules produced by the algorithms for February 5th (winter).




Fig. 6. The schedules produced by the algorithms for the spring day, March 24th. The second robust algorithm produces the same schedule as the nominal algorithm.

has an average reduction in excess cost of about 51%. This is expected considering the discussion in Section 3.3, as the first robust algorithm has an uncertainty set of the form (7) and the second robust algorithm has an uncertainty set of the form (8).

## 5. Conclusion

We considered the economic dispatch problem with uncertain demand for a single micro gas turbine, providing combined heat and power, coupled with utility. We considered the case in which the demand is assumed to be contained in a given uncertainty set and showed an equivalence between the economic dispatch problem and the robust shortest-path problem. Two different models of an uncertainty set were proposed: one including time-dependent confidence intervals with no further assumption, and another coupling with a budgeting assumption throughout the time horizon. Both algorithms relied on adaptations of the classical shortest-path problem, and we presented proofs for




Fig. 7. The schedules produced by the algorithms for the summer day, June 28th. The first robust algorithm produces the same schedule as the nominal algorithm, and the second robust algorithm produces a similar schedule to the benchmark.




Fig. 8. The schedules produced by the algorithms for the autumn day, September 19th. The first robust algorithm produces the same schedule as the nominal algorithm, and the second robust algorithm produces the same result as the benchmark.

Table 1

Schedule costs for the benchmark algorithm, the nominal algorithm, and the two robust algorithms. The reduction of excess costs for the robust algorithms compared to the nominal algorithm is displayed in parentheses. The costs associated with the best-performing algorithm in each day are highlighted by italics.

Schedule cost in \$	Winter Feb. 5th	Spring Mar. 24th	Summer Jun. 28th	Autumn Sep. 19th
Benchmark case	293.02	196.86	188.83	126.48
Nominal algorithm	299.39	202.30	191.35	133.32
First robust algorithm	<i>298.48</i> (14.29%)	<i>202.16</i> (2.57%)	191.35 (0.00%)	133.32 (0.00%)
Second robust algorithm	299.16 (3.61%)	202.30 (0.00%)	<i>188.83</i> (100.00%)	<i>126.48</i> (100.00%)

their correctness and analyses of their time complexity. Both proposed algorithms were demonstrated in a case study, in which we examined their performance under realistic demand framework and tariffs of a residential unit. Our results indicate that the robust algorithms proposed in this manuscript with forecasted demand and uncertainty sets outperform the nominal, non-robust algorithm with forecasted demand. More precisely, when the benchmark algorithm displays heat-driven behavior, the  $\mathcal{L}_\infty$ -norm robust algorithm outperforms the nominal algorithm. Moreover, in electricity-driven and maintenance-cost driven settings, the mixed-norm robust algorithm outperforms the nominal algorithm, and actually reaches the globally optimal schedule stemming from a fully known heat and power demand.

This is a first step toward a robust integration of micro gas turbines with complex models and restrictions into a micro-grid setting, which cannot deterministically predict the future demand. The presented methods can also be applied to the case of arrays of multiple gas turbines by defining  $x(t)$  as a tuple including the states of all the turbines in the array. Unfortunately, this methods scales exponentially with the number of turbines, so it can only be applied to modest size arrays. Future work can try to improve the performance of the algorithms on large turbine arrays by either partitioning the corresponding robust shortest path problem to multiple smaller problems, or by using dual-gradient methods, which will apply the robust algorithms described herein as intermediate steps when calculating the gradient. Another possible avenue for future research is the development of more complex scheduling strategies which consider updates in the demand uncertainty over time. The demand uncertainty can change when a part of the unknown demand is revealed. Such methods can use a rolling-horizon, receding-horizon or a model-predictive control approach, all relying on iterative optimization over time, and will therefore rely on the robust-shortest path algorithms developed in this paper.

## Declaration of competing interest

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

## Acknowledgments

The authors acknowledge the financial support of Minerva Research Center for Micro Turbine Powered Energy Systems (Max Planck Society Contract AZ5746940764), the Startups in Energy Program of the Israeli Ministry of Energy (Contract 20180805), and the Grand Technion Energy Program (GTEP). The first author thanks Dean Leitersdorf for helpful discussions.

## References

- [1] Pilavachi P. Mini-and micro-gas turbines for combined heat and power. *Appl Therm Eng* 2002;22(18):2003–14.
- [2] Gu W, Wu Z, Bo R, Liu W, Zhou G, Chen W, Wu Z. Modeling, planning and optimal energy management of combined cooling, heating and power microgrid: A review. *Int J Electr Power Energy Syst* 2014;54:26–37.
- [3] Liu M, Shi Y, Fang F. Combined cooling, heating and power systems: A survey. *Renew Sustain Energy Rev* 2014;35:1–22.
- [4] Mongibello L, Bianco N, Caliano M, Graditi G. Influence of heat dumping on the operation of residential micro-CHP systems. *Appl Energy* 2015;160:206–20.
- [5] Pantaleo A, Camporeale S, Shah N. Thermo-economic assessment of externally fired micro-gas turbine fired by natural gas and biomass: Applications in Italy. *Energy Convers Manage* 2013;75:202–13.
- [6] Rist JF, Dias MF, Palman M, Zelazo D, Cukurel B. Economic dispatch of a single micro-gas turbine under CHP operation. *Appl Energy* 2017;200:1–18.
- [7] Technical and Service manual. Capstone microturbine, model C65. 2020. <https://www.capstoneturbine.com/> [Accessed 2020-08-08].
- [8] AMT NIKE manual and engine log. 2020. <http://www.amtjets.com/Nike.php> [Accessed: 2020-08-08].
- [9] Lee FN, Breipohl AM. Reserve constrained economic dispatch with prohibited operating zones. *IEEE Trans Power Syst* 1993;8(1):246–54.



- [10] Papageorgiou LG, Fraga ES. A mixed integer quadratic programming formulation for the economic dispatch of generators with prohibited operating zones. *Electr Power Syst Res* 2007;77(10):1292–6.
- [11] USA Federal Aviation Administration. Rules and regulations. In: *Federal Register*, Vol. 71, No. 188. 2006, p. 56864–6, <https://www.govinfo.gov/content/pkg/FR-2006-09-28/pdf/FR-2006-09-28.pdf> [Accessed: 2020-08-08].
- [12] Capece VR, EL-Aini YM. Stall flutter prediction techniques for fan and compressor blades. *J Propul Power* 1996;12(4):800–6.
- [13] Bendiksen O. Recent developments in flutter suppression techniques for turbomachinery rotors. *J Propul Power* 1988;4(2):164–71.
- [14] Lieuwen TC, Yang V. *Gas Turbine Emissions*. Cambridge University Press; 2013.
- [15] Keller JJ. Thermoacoustic oscillations in combustion chambers of gas turbines. *AIAA J* 1995;33(12).
- [16] Lieuwen TC, Yang V. *Combustion Instabilities in Gas Turbine Engines: Operational Experience, Fundamental Mechanisms and Modeling*. American Institute of Aeronautics and Astronautics; 2006.
- [17] Happ HH. Optimal power dispatch - A comprehensive survey. *IEEE Trans Power Appar Syst* 1977;96(3):841–54.
- [18] Wood AJ, Wollenberg BF, Sheblé GB. *Power Generation, Operation, and Control*. John Wiley & Sons; 2013.
- [19] Bertsekas D, Lauer G, Sandell N, Posbergh T. Optimal short-term scheduling of large-scale power systems. *IEEE Trans Automat Control* 1983;28(1):1–11.
- [20] Zelazo D, Dai R, Mesbahi M. An energy management system for off-grid power systems. *Energy Syst* 2012;3(2):153–79.
- [21] Binetti G, Davoudi A, Lewis FL, Naso D, Turchiano B. Distributed consensus-based economic dispatch with transmission losses. *IEEE Trans Power Syst* 2014;29(4):1711–20.
- [22] Kim MJ, Kim TS, Flores RJ, Brouwer J. Neural-network-based optimization for economic dispatch of combined heat and power systems. *Appl Energy* 2020;265:114785.
- [23] Zhou S, Hu Z, Gu W, Jiang M, Chen M, Hong Q, Booth C. Combined heat and power system intelligent economic dispatch: A deep reinforcement learning approach. *Int J Electr Power Energy Syst* 2020;120:106016.
- [24] Gaing Z-L. Particle swarm optimization to solving the economic dispatch considering the generator constraints. *IEEE Trans Power Syst* 2003;18(3):1187–95.
- [25] Xin-gang Z, Ji L, Jin M, Ying Z. An improved quantum particle swarm optimization algorithm for environmental economic dispatch. *Expert Syst Appl* 2020;152:113370.
- [26] Kazda K, Li X. A critical review of the modeling and optimization of combined heat and power dispatch. *Processes* 2020;8(4):441.
- [27] Wen G, Yu X, Liu Z. Recent progress on the study of distributed economic dispatch in smart grid: an overview. *Front Inf Technol Electron Eng* 2021;22(1):25–39.
- [28] Saravanan B, Das S, Sikri S, Kothari D. A solution to the unit commitment problem — a review. *Front Energy* 2013;7(2):223–36.
- [29] Cormen TH, Leiserson CE, Rivest RL, Stein C. *Introduction to algorithms*. MIT Press; 2009.
- [30] Hindi K, Ab Ghani M. Dynamic economic dispatch for large scale power systems: a Lagrangian relaxation approach. *Int J Electr Power Energy Syst* 1991;13(1):51–6.
- [31] Ross DW, Kim S. Dynamic economic dispatch of generation. *IEEE Trans Power Appar Syst* 1980;PAS-99(6):2060–8.
- [32] Kanchev VLH, Colas F, Francois B. Emission reduction and economical optimization of an urban microgrid operation including dispatched PV-based active generators. *IEEE Trans Sustain Energy* 2014;5(4):1397–405.
- [33] Shamsi P, Xie H, Longe A, Joo J. Economic dispatch for an agent-based community microgrid. *IEEE Trans Smart Grid* 2016;7(5):2317–24.
- [34] Gross G, Galiana FD. Short-term load forecasting. *Proc IEEE* 1987;75(12):1558–73.
- [35] Akay D, Atak M. Grey prediction with rolling mechanism for electricity demand forecasting of Turkey. *Energy* 2007;32(9):1670–5.
- [36] Yu C, Mirowski P, Ho TK. A sparse coding approach to household electricity demand forecasting in smart grids. *IEEE Trans Smart Grid* 2017;8(2):738–48.
- [37] Mirasgedis S, Sarafidis Y, Georgopoulou E, Lalas D, Moschovits M, Karagiannis F, Papakonstantinou D. Models for mid-term electricity demand forecasting incorporating weather influences. *Energy* 2006;31(2):208–27.
- [38] Ben-Tal A, El Ghaoui L, Nemirovski A. *Robust Optimization*, Vol. 28. Princeton University Press; 2009.
- [39] Elsayed W, Hegazy Y, Bendary F, El-Bages M. A review on accuracy issues related to solving the non-convex economic dispatch problem. *Electr Power Syst Res* 2016;141:325–32.
- [40] Zhao J, Wen F, Xue Y, Dong Z, Xin J. Power system stochastic economic dispatch considering uncertain outputs from plug-in electric vehicles and wind generators. *Dianli Xitong Zidonghua (Autom Electric Power Syst)* 2010;34(20):22–9.
- [41] Hetzer J, David CY, Bhattarai K. An economic dispatch model incorporating wind power. *IEEE Trans Energy Convers* 2008;23(2):603–11.
- [42] Dhillon J, Parti S, Kothari D. Stochastic economic emission load dispatch. *Electr Power Syst Res* 1993;26(3):179–86.
- [43] Bertsimas D, Sim M. The price of robustness. *Oper Res* 2004;52(1):35–53.
- [44] Yu G, Yang J. On the robust shortest path problem. *Comput Oper Res* 1998;25(6):457–68.
- [45] Bondy J, Murty U. *Graph Theory with Applications*. Macmillan; 1977.
- [46] Rockafellar RT. *Convex Analysis*, no. 28. Princeton University Press; 1970.
- [47] Yaman H, Karasan OE, Pinar MC. The robust spanning tree problem with interval data. *Oper Res Lett* 2001;29(1):31–40.
- [48] Montemanni R, Gambardella LM. An exact algorithm for the robust shortest path problem with interval data. *Comput Oper Res* 2004;31(10):1667–80.
- [49] Bertsimas D, Sim M. Robust discrete optimization and network flows. *Math Program* 2003;98(1–3):49–71.
- [50] Gabrel V, Murat C, Wu L. New models for the robust shortest path problem: complexity, resolution and generalization. *Ann Oper Res* 2013;207(1):97–120.
- [51] Zhang Y, Song S, Shen ZM, Wu C. Robust shortest path problem with distributional uncertainty. *IEEE Trans Intell Transp Syst* 2018;19(4):1080–90.
- [52] Martin A, Müller JC, Pokutta S. Strict linear prices in non-convex European day-ahead electricity markets. *Optim Methods Softw* 2014;29(1):189–221.
- [53] Schiro DA, Zheng T, Zhao F, Litvinov E. Convex hull pricing in electricity markets: Formulation, analysis, and implementation challenges. *IEEE Trans Power Syst* 2016;31(5):4068–75.
- [54] Beaudin M, Zareipour H. Home energy management systems: A review of modelling and complexity. *Renew Sustain Energy Rev* 2015;45:318–35.
- [55] Majumdar S. Low-cycle fatigue and creep analysis of gas turbine engine components. *J Aircr* 1975;12(4):376–82.
- [56] Commercial reference buildings. 2020, <http://energy.gov/eere/buildings/commercial-reference-buildings> [Accessed 2020-08-31].
- [57] Building characteristics for residential hourly load data: based on building America house simulation protocols. 2020, <http://en.openei.org/doe-opendata/dataset/eaddfb10-67a2-4f64-a394-3176c7b686c1/resource/cd6704ba-3f53-4632-8d08-c9597842fde3/download/buildingcharacteristicsforresidentialhourlyloaddata.pdf> [Accessed 2020-08-31].
- [58] Commercial and Residential Hourly Load Profiles for all TMY3 Locations in the United States. Office of energy efficiency & renewable energy (EERE). 2020, <https://openet.org/datasets/dataset/commercial-and-residential-hourly-load-profiles-for-all-tmy3-locations-in-the-united-states> [Accessed 2020-08-31].
- [59] Tariff for electric service residential. PSEG LINY. 2016, Accessed 2020-08-31.
- [60] U.S. natural gas prices. U.S. energy information administration. 2020, [https://www.eia.gov/dnav/ng/ng\\_pri\\_sum\\_dcu\\_nus\\_m.html](https://www.eia.gov/dnav/ng/ng_pri_sum_dcu_nus_m.html) [Accessed 2020-08-31].